

Top 10 List


Inspector Name: ALL

Checklist: All Checklists

Date Range: 7/1/2015 - 6/30/2016

Top 10 Negative Observations

Rating	Category	Freq	Inspection Item
1	Electrical	41	Extension cords have ground pin? (1926.404)
2	Fall Protection	32	Fall protection provided when working above 6 feet? (1926.501)
3	PPE	26	Eye protection used as required? (1926.102)
4	Electrical	24	GFCI used for temporary power connections? (1926.404)
5	Electrical	22	Electrical panels/circuits effectively enclosed? (1926.405)
6	Electrical	20	Employees avoid working near unprotected energized circuits? (1926.416)
7	Electrical	19	Extension cords not worn/frayed? (1926.416)
8	Ladders/Stairs	18	Top 2 steps of stepladder not used? (1926.1053)
9	Fall Protection	15	Top and mid-rail in place and at proper height? (1926.502)
10	Cranes/Rigging	13	Rigging equipment inspected/good condition? (1926.251)



Top 10 List

Inspector Name: ALL

Checklist: All Checklists

Date Range: 7/1/2015 - 6/30/2016

Top 10 Positive Observations

Rating	Category	Freq	Inspection Item
1	PPE	616	PPE provided/used as required? (1926.95)
2	PPE	510	Safety footwear worn as needed? (1926.28)
3	Medical/FA Services	493	First aid supplies easily accessible when required? (1926.50)
4	PPE	462	Hard hats worn as required? (1926.100)
5	PPE	457	Eye protection used as required? (1926.102)
6	Medical/FA Services	455	Certified FA provider available at remote worksites? (1926.50)
7	PPE	409	PPE maintained in good condition? (1926.95)
8	Housekeeping	397	Worksite reasonably organized/good housekeeping? (1926.25)
9	PPE	383	Replacement PPE readily available? (Best Practice)
10	Tools (Hand & Power)	378	Hand and power tools in safe operating condition? (1926.300)

